

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414

ALTERNATIVE ENERGY GENERATION

I. OBJECTIVE

- A. To establish criteria for serving members operating cogeneration and small power production facilities.

II. POLICY

It is the policy of Central Electric Cooperative, Inc. ("the Cooperative") to permit and encourage Alternative Energy System (AES)/Qualifying Facility (QF) Owners to operate cogeneration and small power production facilities and safely and reliably interconnect them with the Cooperative's electric distribution system. The term AES/QF shall be used throughout this document to define any form of generation that is not owned and operated by the Cooperative, and is interconnected to the Cooperative. Alternative Energy Systems are defined under Pennsylvania's Alternative Energy Portfolio Standards Act of 2004 (Act 213-2004). Qualifying Facilities (QF) are defined under the Public Utility Regulatory Policies Act of 1978 (PURPA). This policy will enable the AES/QF Owner to deliver total or excess energy into the Cooperative's distribution system. Compensation for such delivered energy shall be based on Allegheny Electric Cooperative's (Allegheny) avoided costs. The interconnection of an AES/QF and the Cooperative's distribution system is subject to the following conditions:

- A. If the AES/QF has nondiscriminatory access to one of the following: (1) independently administered, auction-based day ahead and real time energy markets and wholesale markets for long-term capacity sales, or (2) an open access transmission and interconnection service provided by a FERC- approved regional transmission organization and competitive wholesale markets that provide an opportunity to sell capacity and energy, then Allegheny's obligation to purchase the energy and capacity generated by a AES/QF may be waived by petitioning FERC for relief from the obligation to purchase energy and capacity on a service territory-wide basis by demonstrating that option (1) or (2) is available to the AES/QF.
- B. Prior to the time of interconnection, the AES/QF Owner must submit to the Cooperative complete and detailed electrical drawings, signed by a licensed Pennsylvania Professional Engineer of the AES/QF or, at the sole discretion of the Cooperative, other documentation of the installation, acceptable to the Cooperative. Such submittal shall be in sufficient detail to provide reasonable assurance that AES/QF complies with all Cooperative and Allegheny requirements. Any new or proposed AES/QF should be evaluated by the Cooperative to determine system impacts. The AES/QF Owner shall provide the Cooperative with appropriate documentation evidencing satisfactory level of completion when the unit is ready to

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414 - CONT'D.

be energized. Written approval must be received from the Cooperative prior to the physical interconnection of the AES/QF to the Cooperative's electric system. The *SAFETY & INTERCONNECTION REQUIREMENTS FOR ALTERNATIVE ENERGY GENERATION* document, included as a supplement to this policy provides additional details regarding the evaluation of proposed generators.

The AES/QF Owner shall be responsible for payment of any incremental costs incurred by the Cooperative or Allegheny to interconnect with, synchronize, or accept output from the AES/QF. This would include, but not be limited to:

1. The costs associated with an engineering or evaluation study to accommodate the AES/QF interconnection.
2. Increase in transformer capacity and service conductor size or length.
3. Change or addition of type of service; e.g.
 - a. Single-phase to three-phase.
 - b. Voltage change (120/240 to 240/480, etc.).
 - c. Metering or disconnect devices
4. Line extension or system upgrade for a AES/QF.
 - a. Single-phase line extension to the facility
 - b. Three-phase line extension to the facility
 - c. Reconductoring a circuit to increase current carrying capability.
 - d. Changes to existing Cooperative protection schemes, including associated communications
 - e. Changes to existing Cooperative voltage regulating schemes, including associated communications.

All AES/QF wiring must be in compliance with the National Electrical Code (NEC) and all other applicable codes and ordinances, and must be approved by an electrical inspection agency acceptable to the Cooperative. Proper grounding is imperative in ensuring safe operation. The latest editions of NEC Article 250 and IEEE Green Book ANSI C114.1-1973 / IEEE 142-1972 should be referenced.

Any reference in this Policy to a code, standard, regulation, or guideline shall be construed to mean the then-current version of that document.

- C. The interconnection equipment must be of a "fail safe" design to ensure, in the event of any electric supply or equipment failure, that the AES/QF and the Cooperative's electric system will be physically separated automatically. To prevent islanding on specific AES/QF applications, a transfer trip scheme may be required. The AES/QF

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414 - CONT'D.

will remain separated until the Cooperative's electric system returns to its normal operating status for a specified minimum amount of time. The AES/QF will synchronize with the Cooperative's electric system only when the Cooperative electric facilities' voltage and frequency are within acceptable industry tolerances. Adherence to IEEE 1547-2018 relaying guidelines is required.

The AES/QF electric system should be able to withstand all expected electric transients that occur on Cooperative's electric distribution and transmission systems, including outages. For instance, fuse coordination and operation of Cooperative reclosers, single-phase or three-phase, should not cause damage that would require repair of the AES/QF's electric system.

The AES/QF Owner shall have the sole responsibility for the safety and electrical protection of his/her AES/QF, without regard to the condition of the Cooperative's or Allegheny's facilities.

- D. The interconnection equipment must include an approved manual, load break safety switch lockable in the open position and be accessible at all times to the Cooperative's personnel. The cooperative may require that the disconnect switch provide a visible opening. The AES/QF Owner shall agree that the Cooperative may open the disconnect switch without prior notice for the following reasons:
1. Emergency conditions on the Cooperative's system.
 2. Inspection of the AES/QF by the Cooperative reveals a hazardous condition or lack of proper maintenance of AES/QF facilities.
 3. The AES/QF interferes with electric service to Cooperative Members or with the Cooperative's electric system. Interference may include, but not be limited to: over or under voltage or frequency, harmonics, etc.
 4. Repair work on the Cooperative's system. Where time permits, the Cooperative will attempt to provide advance notice to the AES/QF Owner of imminent disconnection of the AES/QF and the reasons for same.
- E. The AES/QF must be operated so that no adverse effect(s) or power quality issue(s) occur to the Cooperative's electric system or to others connected thereto. If such adverse effect(s) occur, the AES/QF Owner must discontinue operation of the AES/QF and take corrective action(s) at the AES/QF Owner's sole expense, as deemed necessary by the Cooperative, and/or industry standards, including IEEE 1547-2018, IEEE 929-2000, and UL1741-2010. Adverse effect(s) and power quality issues include, but are not limited to, voltage regulation, flicker, power factor and/or harmonics.

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414 - CONT'D

- F. The AES/QF Owner must inform the Cooperative of any changes to the AES/QF and obtain the Cooperative's approval, in writing, before changes are made to the AES/QF in order to address the adverse effect(s) referred to in Paragraph D above. Prior to reconnecting, the AES/QF Owner must inform the Cooperative of their intent to reconnect.
- G. The AES/QF Owner will own, install, and maintain at his expense, all safety and interconnection equipment as specified by the Cooperative. Minimum required interconnection facilities are described in Section B hereto. The Cooperative reserves the right to observe and witness the installation and testing of interconnection facilities pursuant to industry practices, codes, and IEEE 1547-2018, IEEE 929-2000, and UL 1741 2010. Cooperative observation, review inspection, or testing shall not be considered either as an endorsement or confirmation of any aspect, feature, element, or condition of the AES/QF or associated interconnection equipment or the operation thereof, nor as a warranty as to the fitness, safety, desirability, or reliability of same. The inspection does not impose any obligation upon the Cooperative or Allegheny to warrant or ensure in any manner the AES/QF's safety or compliance with this Agreement. Further, the Cooperative and Allegheny made no representations concerning, and expressly disclaim any expertise or specialized knowledge relating to the particular type of generation employed by the Generator or equipment associated with such generation.
- H. The AES/QF must be installed to meet the most recent edition of the National Electrical Safety Code (NESC) or other applicable code requirements for clearances from the nearest Cooperative electric facility, or such other distance as the Cooperative deems necessary for safety or electric operation-related reasons.
- I. The Cooperative and/or Allegheny reserves the right to inspect the AES/QF, interconnection equipment and associated maintenance records at any time. Such inspections shall not relieve the AES/QF Owner from his/her obligation to operate and maintain the AES/QF in a safe and satisfactory manner.
- J. Consistent with the provisions of 7 CFR 1730 Subpart C, "Interconnection of Distributed Resources", the cooperative sets forth the following insurance requirements for AES/QF Owners.

The cooperative has determined that it has in effect appropriate liability insurance of its own covering the cooperative's operations, including interconnections. AES/QF Owners other than residential consumer-members must have a current liability insurance policy adequate in amount to cover all forms of liability that may arise from the operation of the AES/QF interconnected to the Cooperative's electric system, and the policy should list the Cooperative as an additional named insured.

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414 - CONT'D

A copy of this policy must be on file with the Cooperative. Lapse of the policy must be automatically reported to the Cooperative by the insurer, and shall result in the immediate disconnection of the AES/QF from the Cooperative's electric system. In general, a minimum of \$1 Million in liability insurance is required, but a more specific amount can be based on the Cooperative's review of the specific AES/QF.

Due in part to 1) the prohibition by the Pennsylvania Public Utility Commission for utilities under its jurisdiction to require a distributed resource owner to provide liability insurance as a condition for obtaining an interconnection, 2) the belief by Commonwealth of Pennsylvania officials that an "insurance requirement" discourages the development of alternative energy resources, 3) the relative small size of residential distributed resources, and 4) the Cooperative desire to encourage the development of renewable resources consistent with state and federal goals, the Cooperative has determined that no additional liability insurance requirement for residential AES/QF installations of 100 kW or smaller is appropriate.

Additionally, residential consumer-members that are AES/QF Owners are encouraged to but are not required to maintain a current liability insurance policy adequate in amount to cover all forms of liability that may arise from the interconnection of the AES/QF interconnected to the Cooperative's electric system.

- K. The AES/QF Owner shall agree to hold the Cooperative and Allegheny harmless and indemnify them in connection with any damages or injury affecting any party resulting from the installation or the interconnection of the AES/QF to the Cooperative's or Allegheny's system, and the purchase of any output from the AES/QF, or operation of the AES/QF. The AES/QF agrees to indemnify the Cooperative and/or Allegheny for any monetary damage, liability, administrative, and/or legal expenses incurred by the Cooperative and/or Allegheny as a result of the failure of the AES/QF to meet any requirement or condition set forth herein.
- L. The AES/QF Owner shall sell its output to Allegheny, pursuant to PURPA or ACT 213-2004 (as applicable) requirements, or upon written notification to Allegheny, to another entity. If another power purchasing entity is selected, a transmission or other charge may apply to wheel or transport the electric power over the Cooperative's or Allegheny's electric facilities. The Cooperative will sell electric energy and capacity to the AES/QF at rates and upon terms and conditions as specified in the Cooperative's applicable rules, regulations, policies, and rate schedules.
- M. When requested by the AES, the Cooperative will provide "net metering" to the AES. To accomplish "net metering" the Cooperative will meter electric flow to and from the AES. Billing for electric flow to the AES and credit for electric flow from the

CENTRAL ELECTRIC COOPERATIVE, INC.

POLICY NUMBER 414 - CONT'D

AES will be as described in the Cooperative's "Net Metering Rate Rider".

The AES/QF is responsible to execute a contract with Allegheny to receive compensation for this excess energy and /or capacity delivered into the Cooperative's electric system during the monthly billing period.

- N. For AES/QF's of 150 kW or less, the AES/QF will be compensated at Allegheny's avoided cost rate.
- O. For AES/QF facilities of more than 150 kW, Allegheny will evaluate the proposed facility and negotiate potential purchase rates on a case-by-case basis, which rates will be based on Allegheny's avoided costs.
- P. Allegheny may refuse to purchase output from a AES/QF from time to time so the Cooperative can (1) construct, install, maintain, repair, replace, remove, investigate or inspect any of the Cooperative's equipment or any part of the Cooperative's System; or (2) if the Cooperative and/or Allegheny determine(s) that curtailment, interruption, or reduction of deliveries of energy or energy and capacity is appropriate because of emergencies, forced outages, operating conditions on the Cooperative's system, or as otherwise required by industry standard electrical practices.
- Q. Synchronous Generators will operate at a power factor required by the Cooperative.

III. RESPONSIBILITY

- A. The President of the Board and CEO & General Manager shall ensure that this policy is adhered to.

Revised: December 18, 2006

Revised: February 8, 2010

Revised: June 20, 2011

Revised: August 19, 2019

Revised: July 17, 2023